



FIRE DEPARTMENT

9 METROTECH CENTER

BROOKLYN, N.Y. 11201-3857

JAMES HANSEN

Director of Engineering and Technical Standards

Bureau of Fire Prevention

Room 3W-02

CERTIFICATE OF APPROVAL # 5021
THIS CERTIFICATE IS REVOCABLE, NOT TRANSFERABLE
AND EXPIRES ON June 11, 2006

June 12, 2003

Mr. Andrew T. Bay
New Product Manager
Franklin Fueling System / EBW Inc.
2817 McCracken Ave
Muskegon, MI 49441

By order of Fire Commissioner Nicholas Scoppetta and pursuant to §27-4015 of the Administrative Code, the following equipment or system is accepted for use provided the conditions as outlined below are in full compliance.

Manufacturer: Franklin Fueling System / EBW Inc.

Product: Catchment basin for underground motor fuel storage tanks

Trade Name: Spill containment with 15 US gallon capacity

Model No: 715-474 Below Grade with a manual drain
715-472 Grade Level with a manual drain

Pertinent Code Section: 3RCNY§21-20 and C-27-4065-f. of NY City Fire Prevention Code
40 CRF 280.20 & 280.30

Testing Laboratory: Underwriters Laboratories of Canada.
Entela, Inc.

Testing Standard: ULC/ORD-C58.19-1992

Test Report: File CMH1667 Application No: 15156
Entela Report No. 03-0505-6005

Issued: October 17, 1995
Date: June 3, 2003

Conditions of Approval:

1. Installation shall comply with all applicable New York City Codes, Rules, Regulations, etc. including but not limit to 3RCNY § 21-20 effective March 21, 2000.

Note: To obtain a copy of the New York City Administrative Fire Code you may contact Citybooks Store at 212-669-8246. For a copy of the Fire Department Rules of the City of New York please contact Command Information Services, Legal Publishing Division at 518-436-8647.

2. The rubber gaskets material used on this spill containment device shall be the same as submitted to Entela, Inc. for testing report #03-0505-6005 and shall not be changed in any way without prior written approval of the Fire Department.
3. Certificate of Approval number shall be plainly and permanently stamped or otherwise fixed upon each device by the manufacturer.
4. Equipment shall have secured and shall maintain all required approvals and shall meet all applicable Federal and State requirements. Manufacturer's installation and maintenance procedures and limitations shall be complied with.
5. The Certificate of approval is issued upon condition that the material or equipment's technology does not violate any patent, trade name, trade secret or other intellectual right.
6. The use of the above spill containment device shall be limited to the indicated intent and has not been acceptable for other uses or applications.
7. The Fire Department Certificate of Approval does not constitute an endorsement or recommendation of your product by the Fire Department, but is a certification that your product, as represented, meets the standards as of the date of issuance.
8. The Fire Department's conditions of approval shall be enumerated in the installation/operation manuals and sales brochures that will be provided to New York City buyers, users and installers.
9. The Fire Department reserves the right to withdraw this approval at any time in the event there is a reasonable doubt that the product does not operate or perform as required by code, the conditions of this resolution or as represented in your application.
10. As the manufacturer of this equipment/material, you should be aware that any end users who fails to comply with the condition as outlined in the approval will be subject to enforcement action which may include fines and imprisonment.

COA # 5021 for Franklin Fueling System / EBW Inc.
Catchment basin for underground motor fuel storage tanks
June 12, 2003
Page 3 of 3.

Any change in company name or ownership, product name, material of construction, product design, or model number of any product included on this certificate must be immediately reported to this Department in writing.

Very truly yours,



James Hansen P.E.
Director of Engineering

JH:AH / 50210506.doc